### SIPROTEC 7SJ64 multifunction protection relay with synchronization



Fig. 5/87 SIPROTEC 7SJ64 multifunction protection relay

#### Description

The SIPROTEC 7SJ64 can be used as a protective control and monitoring relay for distribution feeders and transmission lines of any voltage in networks that are earthed (grounded), low-resistance grounded, ungrounded, or of a compensated neutral point structure. The relay is suited for networks that are radial or looped, and for lines with single or multi-terminal feeds. The SIPROTEC 7SJ64 is equipped with a synchronization function which provides the operation modes 'synchronization check' (classical) and 'synchronous/asynchronous switching' (which takes the CB mechanical delay into consideration). Motor protection comprises undercurrent monitoring, starting time supervision, restart inhibit, locked rotor, load jam protection as well as motor statistics.

The 7SJ64 is featuring the "flexible protection functions". Up to 20 protection functions can be added according to individual requirements. Thus, for example, rate-of-frequency-change protection or reverse power protection can be implemented.

The relay provides easy-to-use local control and automation functions. The number of controllable switchgear depends only on the number of available inputs and outputs. The integrated programmable logic (CFC) allows the user to implement their own functions, e.g. for the automation of switchgear (interlocking). CFC capacity is much larger compared to 7SJ63 due to extended CPU power. The user is able to generate user-defined messages as well.

The flexible communication interfaces are open for modern communication architectures with control systems.

### **Function overview**

### Protection functions

- Overcurrent protection
- Directional overcurrent protection
- Sensitive dir./non-dir. ground-fault detection
- Displacement voltage
- · Intermittent ground-fault protection
- Directional intermittent ground fault protection
- High-impedance restricted ground fault
- Inrush restraint
- Motor protection
- Overload protection
- Temperature monitoring
- Under-/overvoltage protection
- Under-/overfrequency protection
- Rate-of-frequency-change protection
- Power protection (e.g. reverse, factor)
- Undervoltage-controlled reactive power protection
- Breaker failure protection
- Negative-sequence protection
- Phase-sequence monitoring
- Synchronization
- Auto-reclosure
- Fault locator
- Lockout

#### Control functions/programmable logic

- · Flexible number of switching devices
- Position of switching elements is shown on the graphic display
- · Local/remote switching via key-operated switch
- · Control via keyboard, binary inputs, DIGSI 4 or SCADA system
- Extended user-defined logic with CFC (e.g. interlocking)

#### **Monitoring functions**

- Operational measured values V, I, f, ...
- Energy metering values W<sub>p</sub>, W<sub>q</sub>
- · Circuit-breaker wear monitoring
- Slave pointer
- Trip circuit supervision
- Fuse failure monitor
- 8 oscillographic fault records
- Motor statistics

#### **Communication interfaces**

- System interface
- IEC 60870-5-103, IEC 61850
- PROFIBUS DP
- DNP 3 / DNP3 TCP / MODBUS RTU
- PROFINET
- Service interface for DIGSI 4 (modem)
- Additional interface for temperature detection (RTD-box)
- Front interface for DIGSI 4
- Time synchronization via IRIG B/DCF77

### Application



#### Fig. 5/88 Function diagram

### Application

The SIPROTEC 7SJ64 unit is a numerical protection relay that also performs control and monitoring functions and therefore supports the user in cost-effective power system management, and ensures reliable supply of electric power to the customers. Local operation has been designed according to ergonomic criteria. A large, easyto-read graphic display was a major design aim.

### Control

The integrated control function permits control of disconnect devices (electrically operated/motorized switches) or circuitbreakers via the integrated operator panel, binary inputs, DIGSI 4 or the control and protection system (e.g. SICAM). The present status (or position) of the primary equipment can be displayed. 7SJ64 supports substations with single and duplicate busbars. The number of elements that can be controlled (usually 1 to 5) is only restricted by the number of inputs and outputs available. A full range of command processing functions is provided.

### Programmable logic

The integrated logic characteristics (CFC) allow users to implement their own functions for automation of switchgear (interlocking) or a substation via a graphic user interface. Due to extended CPU power, the programmable logic capacity is much larger compared to 7SJ63. The user can also generate user-defined messages.

### Line protection

The 7SJ64 units can be used for line protection of high and medium-voltage networks with grounded, low-resistance grounded, isolated or compensated neutral point.

### Synchronization

In order to connect two components of a power system, the relay provides a synchronization function which verifies that switching ON does not endanger the stability of the power system.

The synchronization function provides the operation modes 'synchro-check' (classical) and 'synchronous/asynchronous switching' (which takes the c.-b. mechanical delay into consideration).

### Motor protection

When protecting motors, the relays are suitable for asynchronous machines of all sizes.

### **Transformer protection**

The 7SJ64 units perform all functions of backup protection supplementary to transformer differential protection. The inrush suppression effectively prevents tripping by inrush currents.

The high-impedance restricted ground-fault protection detects short-circuits and insulation faults of the transformer.

### **Backup protection**

The relays can be used universally for backup protection.

#### Flexible protection functions

By configuring a connection between a standard protection logic and any measured or derived quantity, the functional scope of the relays can be easily expanded by up to 20 protection stages or protection functions.

#### Metering values

Extensive measured values, limit values and metered values permit improved system management.

## Application

ANSI	IEC	Protection functions
50, 50N	I>, I>>, I>>> I <sub>E</sub> >, I <sub>E</sub> >>>, I <sub>E</sub> >>>	Definite-time overcurrent protection (phase/neutral)
50, 50N	I>>>>, I <sub>2</sub> > I <sub>E</sub> >>>>	Additional definite-time overcurrent protection stages (phase/neutral) via flexible protection functions
51, 51V, 51N	I <sub>p</sub> , I <sub>Ep</sub>	Inverse overcurrent protection (phase/neutral), phase function with voltage-dependent option
67, 67N	$I_{dir}$ >, $I_{dir}$ >>, $I_{p dir}$ $I_{Edir}$ >, $I_{Edir}$ >, $I_{Ep dir}$	Directional overcurrent protection (definite/inverse, phase/neutral), Directional comparison protection
67Ns/50Ns	$I_{EE}$ >, $I_{EE}$ >>, $I_{EEp}$	Sensitive ground-fault protection
-		Cold load pick-up (dynamic setting change)
59N/64	V <sub>E</sub> , V <sub>0</sub> >	Displacement voltage, zero-sequence voltage
-	<i>I</i> <sub>IE</sub> >	Intermittent ground fault
67Ns	I <sub>IE dir</sub> >	Directional intermittent ground fault protection
87N		High-impedance restricted ground-fault protection
50BF		Breaker failure protection
(79M)		Auto-reclosure
25		Synchronization
(46)	<i>I</i> <sub>2</sub> >	Phase-balance current protection (negative-sequence protection)
(47)	V <sub>2</sub> >, phase seq.	Unbalance-voltage protection and/or phase-sequence monitoring
(49)	θ>	Thermal overload protection
(48)		Starting time supervision
51M		Load jam protection
(14)		Locked rotor protection
66/86		Restart inhibit
37	I<	Undercurrent monitoring
38		Temperature monitoring via external device (RTD-box), e.g. bearing temperature monitoring
27, 59	V<, V>	Undervoltage/overvoltage protection
59R	dV/dt	Rate-of-voltage-change protection
32	P<>, Q<>	Reverse-power, forward-power protection
27/Q	Q>/V<	Undervoltage-controlled reactive power protection
35)	$\cos \varphi$	Power factor protection
810/U	f>, f<	Overfrequency/underfrequency protection
81R	df/dt	Rate-of-frequency-change protection
21FL		Fault locator

### Construction

### Construction

## Connection techniques and housing with many advantages

#### $1\!\!/_3$ , $1\!\!/_2$ and $1\!\!/_1\text{-rack}$ sizes

These are the available housing widths of the 7SJ64 relays, referred to a 19" module frame system. This means that previous models can always be replaced. The height is a uniform 244 mm for flush-mounting housings and 266 mm for surface-mounting housings for all housing widths. All cables can be connected with or without ring lugs. Plug-in terminals are available as an option.

It is thus possible to employ prefabricated cable harnesses. In the case of surface mounting on a panel, the connection terminals are located above and below in the form of screw-type terminals. The communication interfaces are located in a sloped case at the top and bottom of the housing. The housing can also be supplied optionally with a detached operator panel (refer to Fig. 5/91), or without operator panel, in order to allow optimum operation for all types of applications.



Fig. 5/89 Flush-mounting housing with screw-type terminals



Fig. 5/90 Front view of 7SJ64 with  $\frac{1}{3} \times 19$ " housing



Fig. 5/91 Housing with plug-in terminals and detached operator panel



Fig. 5/92 Surface-mounting housing with screw-type terminals



Fig. 5/93 Communication interfaces in a sloped case in a surface-mounting housing

### **Protection functions**

### **Protection functions**

### Overcurrent protection (ANSI 50, 50N, 51,51V, 51N)

This function is based on the phaseselective measurement of the three phase currents and the ground current (four transformers). Three definite-time overcurrent protection elements (DMT) exist both for the phases and for the ground. The current threshold and the delay time can be set in a wide range. In addition, inverse-time overcurrent protection characteristics (IDMTL) can be activated. The inverse-time function provides – as an option - voltage-restraint or voltagecontrolled operating modes. With the "flexible protection functions", further definite-time overcurrent stages can be implemented in the 7SJ64 unit.

### **Reset characteristics**

For easier time coordination with electromechanical relays, reset characteristics according to ANSI C37.112 and IEC 60255-3 / BS 142 standards are applied.

When using the reset characteristic (disk emulation), a reset process is initiated after the fault current has disappeared. This reset process corresponds to the reverse movement of the Ferraris disk of an electromechanical relay (thus: disk emulation).

### **User-definable characteristics**

Instead of the predefined time characteristics according to ANSI, tripping characteristics can be defined by the user for phase and ground units separately. Up to 20 current/time value pairs may be programmed. They are set as pairs of numbers or graphically in DIGSI 4.

#### Inrush restraint

The relay features second harmonic restraint. If the second harmonic is detected during transformer energization, pickup of non-directional and directional normal elements are blocked.

#### Cold load pickup/dynamic setting change

For directional and nondirectional overcurrent protection functions the initiation thresholds and tripping times can be switched via binary inputs or by time control.





Fig. 5/94 Definite-time overcurrent protection





Available inverse-time characteristics					
Characteristics acc. to	ANSI/IEEE	IEC 60255-3			
Inverse	•	•			
Short inverse	•				
Long inverse	•	•			
Moderately inverse	•				
Very inverse	•	•			
Extremely inverse	•	•			
Definite inverse	•				

### **Protection functions**

### Directional overcurrent protection (ANSI 67, 67N)

Directional phase and ground protection are separate functions. They operate in parallel to the non-directional overcurrent elements. Their pickup values and delay times can be set separately. Definite-time and inverse-time characteristic is offered. The tripping characteristic can be rotated about  $\pm$  180 degrees.

By means of voltage memory, directionality can be determined reliably even for close-in (local) faults. If the switching device closes onto a fault and the voltage is too low to determine direction, directionality (directional decision) is made with voltage from the voltage memory. If no voltage exists in the memory, tripping occurs according to the coordination schedule.

For ground protection, users can choose whether the direction is to be determined via zero-sequence system or negativesequence system quantities (selectable).

Using negative-sequence variables can be advantageous in cases where the zero voltage tends to be very low due to unfavorable zero-sequence impedances.

### Directional comparison protection (cross-coupling)

It is used for selective protection of sections fed from two sources with instantaneous tripping, i.e. without the disadvantage of time coordination. The directional comparison protection is suitable if the distances between the protection stations are not significant and pilot wires are available for signal transmission. In addition to the directional comparison protection, the directional coordinated overcurrent protection is used for complete selective backup protection. If operated in a closed-circuit connection, an interruption of the transmission line is detected.

## (Sensitive) directional ground-fault detection (ANSI 64, 67Ns/67N)

For isolated-neutral and compensated networks, the direction of power flow in the zero sequence is calculated from the zerosequence current  $I_0$  and zero-sequence voltage  $V_0$ . For networks with an isolated neutral, the reactive current component is evaluated; for compensated networks, the active current component or residual resistive current is evaluated.

For special network conditions, e.g. high-resistance grounded networks with ohmic-capacitive ground-fault current or low-resistance grounded networks with ohmic-inductive current, the tripping characteristics can be rotated approximately  $\pm$  45 degrees.

Two modes of ground-fault direction detection can be implemented: tripping or "signalling only mode".

It has the following functions:

- TRIP via the displacement voltage  $V_{\rm E}$ .
- Two instantaneous elements or one instantaneous plus one user-defined characteristic.
- Each element can be set in forward, reverse, or nondirectional.
- The function can also be operated in the insensitive mode, as an additional short-circuit protection.

### (Sensitive) ground-fault detection (ANSI 50Ns, 51Ns/50N, 51N)

For high-resistance grounded networks, a sensitive input transformer is connected to a phase-balance neutral current transformer (also called core-balance CT).



Fig. 5/96 Directional characteristic of the directional overcurrent protection



Fig. 5/97 Directional determination using cosine measurements for compensated networks

The function can also be operated in the insensitive mode, as an additional short-circuit protection.

### Intermittent ground-fault protection

Intermittent (re-striking) faults occur due to insulation weaknesses in cables or as a result of water penetrating cable joints. Such faults either simply cease at some stage or develop into lasting short-circuits. During intermittent activity, however, star-point resistors in networks that are impedance-grounded may undergo thermal overloading. The normal ground-fault protection cannot reliably detect and interrupt the current pulses, some of which can be very brief.

The selectivity required with intermittent ground faults is achieved by summating the duration of the individual pulses and by triggering when a (settable) summed time is reached. The response threshold  $I_{\rm IE}$ > evaluates the r.m.s. value, referred to one systems period.

### **Protection functions**

### Directional intermittent ground fault protection (ANSI 67Ns)

The directional intermittent ground fault protection has to detect intermittent ground faults in resonant grounded cable systems selectively. Intermittent ground faults in resonant grounded cable systems are usually characterized by the following properties:

- A very short high-current ground current pulse (up to several hundred amperes) with a duration of under 1 ms
- They are self-extinguishing and re-ignite within one halfperiod up to several periods, depending on the power system conditions and the fault characteristic.
- Over longer periods (many seconds to minutes), they can develop into static faults.

Such intermittent ground faults are frequently caused by weak insulation, e.g. due to decreased water resistance of old cables. Ground fault functions based on fundamental component measured values are primarily designed to detect static ground faults and do not always behave correctly in case of intermittent ground faults. The function described here evaluates specifically the ground current pulses and puts them into relation with the zero-sequence voltage to determine the direction.

#### Phase-balance current protection (ANSI 46) (Negative-sequence protection)

In line protection, the two-element phase-balance current/ negative-sequence protection permits detection on the high side of high-resistance phase-to-phase faults and phase-to-ground faults that are on the low side of a transformer (e.g. with the switch group Dy 5). This provides backup protection for highresistance faults beyond the transformer.

### Breaker failure protection (ANSI 50BF)

If a faulted portion of the electrical circuit is not disconnected upon issuance of a trip command, another command can be initiated using the breaker failure protection which operates the circuit-breaker, e.g. of an upstream (higher-level) protection relay. Breaker failure is detected if, after a trip command, current is still flowing in the faulted circuit. As an option, it is possible to make use of the circuit-breaker position indication.

### Auto-reclosures (ANSI 79)

Multiple reclosures can be defined by the user and lockout will occur if a fault is present after the last reclosure. The following functions are possible:

- 3-pole ARC for all types of faults
- Separate settings for phase and ground faults
- Multiple ARC, one rapid auto-reclosure (RAR) and up to nine delayed auto-reclosures (DAR)
- Starting of the ARC depends on the trip command selection (e.g. 46, 50, 51, 67)
- Blocking option of the ARC via binary inputs
- ARC can be initiated externally or via CFC
- The directional and non-directional elements can either be blocked or operated non-delayed depending on the autoreclosure cycle
- Dynamic setting change of the directional and non-directional elements can be activated depending on the ready AR
- The AR CLOSE command can be given synchronous by use of the synchronization function.



Fig. 5/98 Flexible protection functions

#### **Flexible protection functions**

The 7SJ64 units enable the user to easily add on up to 20 protective functions. To this end, parameter definitions are used to link a standard protection logic with any chosen characteristic quantity (measured or derived quantity) (Fig. 5/98). The standard logic consists of the usual protection elements such as the pickup message, the parameter-definable delay time, the TRIP command, a blocking possibility, etc. The mode of operation for current, voltage, power and power factor quantities can be three-phase or single-phase. Almost all quantities can be operated as greater than or less than stages. All stages operate with protection priority.

Protection stages/functions attainable on the basis of the available characteristic quantities:

Function	ANSI No.
<i>I</i> >, <i>I</i> <sub>E</sub> >	50, 50N
$V <, V >, V_E >, dV/dt$	27, 59, 59R, 64
3 <i>I</i> <sub>0</sub> >, <i>I</i> <sub>1</sub> >, <i>I</i> <sub>2</sub> >, <i>I</i> <sub>2</sub>   <i>I</i> <sub>1</sub> , 3 <i>V</i> <sub>0</sub> >, <i>V</i> <sub>1</sub> ><, <i>V</i> <sub>2</sub> ><	50N, 46, 59N, 47
P><, Q><	32
$\cos \varphi$ (p.f.)><	55
f><	81O, 81U
df/dt><	81R

For example, the following can be implemented:

- Reverse power protection (ANSI 32R)
- Rate-of-frequency-change protection (ANSI 81R)

## Undervoltage-controlled reactive power protection (ANSI 27/Q)

The undervoltage-controlled reactive power protection protects the system for mains decoupling purposes. To prevent a voltage collapse in energy systems, the generating side, e.g. a generator, must be equipped with voltage and frequency protection devices. An undervoltage-controlled reactive power protection is required at the supply system connection point. It detects critical power system situations and ensures that the power generation facility is disconnected from the mains. Furthermore, it ensures that reconnection only takes place under stable power system conditions. The associated criteria can be parameterized.

### **Protection functions**

### Synchronization (ANSI 25)

 In case of switching ON the circuit-breaker, the units can check whether the two subnetworks are synchronized (classic synchro-check). Furthermore, the synchronizing function may operate in the "Synchronous/asynchronous switching" mode. The unit then distinguishes between synchronous and asynchronous networks:

In synchronous networks, frequency differences between the two subnetworks are almost non-existant. In this case, the circuit-breaker operating time does not need to be considered. Under asynchronous condition, however, this difference is markedly larger and the time window for switching is shorter. In this case, it is recommended to consider the operating time of the circuit- breaker.

The command is automatically pre-dated by the duration of the operating time of the circuit-breaker, thus ensuring that the contacts of the CB close at exactly the right time.

Up to 4 sets of parameters for the synchronizing function can be stored in the unit. This is an important feature when several circuit-breakers with different operating times are to be operated by one single relay.

### Thermal overload protection (ANSI 49)

For protecting cables and transformers, an overload protection with an integrated pre-warning element for temperature and current can be applied. The temperature is calculated using a thermal homogeneous-body model (according to IEC 60255-8), which takes account both of the energy entering the equipment and the energy losses. The calculated temperature is constantly adjusted accordingly. Thus, account is taken of the previous load and the load fluctuations.

For thermal protection of motors (especially the stator), a further time constant can be set so that the thermal ratios can be detected correctly while the motor is rotating and when it is stopped. The ambient temperature or the temperature of the coolant can be detected serially via an external temperature monitoring box (resistance-temperature detector box, also called RTD- box). The thermal replica of the overload function is automatically adapted to the ambient conditions. If there is no RTD-box it is assumed that the ambient temperatures are constant.

### High-impedance restricted ground-fault protection (ANSI 87N)

The high-impedance measurement principle is an uncomplicated and sensitive method for detecting ground faults, especially on transformers. It can also be applied to motors, generators and reactors when these are operated on an grounded network.

When the high-impedance measurement principle is applied, all current transformers in the protected area are connected in parallel and operated on one common resistor of relatively high R whose voltage is measured (see Fig. 5/99). In the case of 7SJ6 units, the voltage is measured by detecting the current through the (external) resistor R at the sensitive current measurement input  $I_{\text{EE}}$ .

The varistor V serves to limit the voltage in the event of an internal fault. It cuts off the high momentary voltage spikes occurring at transformer saturation. At the same time, this results in smoothing of the voltage without any noteworthy reduction of the average value. If no faults have occurred and in the event of external faults, the system is at equilibrium, and the voltage through the resistor is approximately zero. In the



Fig. 5/99 High-impedance restricted ground-fault protection

event of internal faults, an imbalance occurs which leads to a voltage and a current flow through the resistor *R*.

The current transformers must be of the same type and must at least offer a separate core for the high-impedance restricted ground-fault protection. They must in particular have the same transformation ratio and an approximately identical knee-point voltage. They should also demonstrate only minimal measuring errors.

### Settable dropout delay times

If the devices are used in parallel with electromechanical relays in networks with intermittent faults, the long dropout times of the electromechanical devices (several hundred milliseconds) can lead to problems in terms of time grading. Clean time grading is only possible if the dropout time is approximately the same. This is why the parameter of dropout times can be defined for certain functions such as time-overcurrent protection, ground short-circuit and phase-balance current protection.

### Motor protection

### Restart inhibit (ANSI 66/86)

If a motor is started up too many times in succession, the rotor can be subject to thermal overload, especially the upper edges of the bars. The rotor temperature is calculated from the stator current. The reclosing lockout only permits start-up of the motor if the rotor has sufficient thermal reserves for a complete startup (see Fig. 5/100).

### **Emergency start-up**

This function disables the reclosing lockout via a binary input by storing the state of the thermal replica as long as the binary input is active. It is also possible to reset the thermal replica to zero.

### Temperature monitoring (ANSI 38)

Up to two temperature monitoring boxes with a total of 12 measuring sensors can be used for temperature monitoring and detection by the protection relay. The thermal status of motors, generators and transformers can be monitored with this device. Additionally, the temperature of the bearings of rotating machines are monitored for limit value violation. The temperatures are being measured with the help of temperature

### **Protection functions**

detectors at various locations of the device to be protected. This data is transmitted to the protection relay via one or two temperature monitoring boxes (see "Accessories", page 5/197).

### Starting time supervision (ANSI 48/14)

Starting time supervision protects the motor against long unwanted start-ups that might occur in the event of excessive load torque or excessive voltage drops within the motor, or if the rotor is locked. Rotor temperature is calculated from measured stator current. The tripping time is calculated according to the following equation:

for  $I > I_{MOTOR START}$ 

$$t = \left(\frac{I_{\mathsf{A}}}{I}\right)^2 \cdot T_{\mathsf{A}}$$

I = Actual current flowing I<sub>MOTOR START</sub> = Pickup current to detect a motor start

t = Tripping time

- $I_{A}$  = Rated motor starting current
- $T_{A}$  = Tripping time at rated motor starting current (2 times, for warm and cold motor)

The characteristic (equation) can be adapted optimally to the state of the motor by applying different tripping times  $T_A$  in dependence of either cold or warm motor state. For differentiation of the motor state the thermal model of the rotor is applied.

If the trip time is rated according to the above formula, even a prolonged start-up and reduced voltage (and reduced start-up current) will be evaluated correctly. The tripping time is inverse (current dependent).

A binary signal is set by a speed sensor to detect a blocked rotor. An instantaneous tripping is effected.

### Load jam protection (ANSI 51M)

Sudden high loads can cause slowing down and blocking of the motor and mechanical damages. The rise of current due to a load jam is being monitored by this function (alarm and tripping).

The overload protection function is too slow and therefore not suitable under these circumstances.

### Phase-balance current protection (ANSI 46) (Negative-sequence protection)

The negative-sequence *l* phase-balance current protection detects a phase failure or load unbalance due to network asymmetry and protects the rotor from impermissible temperature rise.

### Undercurrent monitoring (ANSI 37)

With this function, a sudden drop in current, which can occur due to a reduced motor load, is detected. This may be due to shaft breakage, no-load operation of pumps or fan failure.



Fig. 5/100

### **Motor statistics**

Essential information on start-up of the motor (duration, current, voltage) and general information on number of starts, total operating time, total down time, etc. are saved as statistics in the device.

### Voltage protection

#### **Overvoltage protection (ANSI 59)**

The two-element overvoltage protection detects unwanted network and machine overvoltage conditions. The function can operate either with phase-to-phase, phase-to-ground, positive phase-sequence or negative phase-sequence voltage. Threephase and single-phase connections are possible.

### Undervoltage protection (ANSI 27)

The two-element undervoltage protection provides protection against dangerous voltage drops (especially for electric machines). Applications include the isolation of generators or motors from the network to avoid undesired operating states and a possible loss of stability. Proper operating conditions of electrical machines are best evaluated with the positivesequence quantities. The protection function is active over a wide frequency range (45 to 55, 55 to 65 Hz)<sup>1)</sup>. Even when falling below this frequency range the function continues to work, however, with a greater tolerance band.

The function can operate either with phase-to-phase, phaseto-ground or positive phase-sequence voltage, and can be monitored with a current criterion. Three-phase and single-phase connections are possible.

### Frequency protection (ANSI 810/U)

Frequency protection can be used for over-frequency and underfrequency protection. Electric machines and parts of the system are protected from unwanted speed deviations. Unwanted frequency changes in the network can be detected and the load can be removed at a specified frequency setting. Frequency protection can be used over a wide frequency range (40 to 60, 50 to

1) The 45 to 55, 55 to 65 Hz range is available for  $f_{\rm N}$  = 50/60 Hz.

### Protection functions, functions

70 Hz)<sup>1)</sup>. There are four elements (selectable as overfrequency or underfrequency) and each element can be delayed separately. Blocking of the frequency protection can be performed if using a binary input or by using an undervoltage element.

### Fault locator (ANSI 21FL)

The integrated fault locator calculates the fault impedance and the distance-to-fault. The results are displayed in  $\Omega$ , kilometers (miles) and in percent of the line length.

### Circuit-breaker wear monitoring

Methods for determining circuit-breaker contact wear or the remaining service life of a circuit-breaker (CB) allow CB maintenance intervals to be aligned to their actual degree of wear. The benefit lies in reduced maintenance costs.

There is no mathematically exact method of calculating the wear or the remaining service life of circuit-breakers that takes into account the arc-chamber's physical conditions when the CB opens. This is why various methods of determining CB wear have evolved which reflect the different operator philosophies. To do justice to these, the devices offer several methods:

- Σ I
- $\Sigma I^{x}$ , with x = 1... 3
- $\Sigma I^2 t$

The devices additionally offer a new method for determining the remaining service life:

• Two-point method

The CB manufacturers double-logarithmic switching cycle diagram (see Fig. 5/101) and the breaking current at the time of contact opening serve as the basis for this method. After CB opening, the two-point method calculates the number of still possible switching cycles. To this end, the two points P1 and P2 only have to be set on the device. These are specified in the CB's technical data. All of these methods are phase-selective and a limit value can be set in order to obtain an alarm if the actual value falls below or exceeds the limit value during determination of the remaining service life.

### Commissioning

Commissioning could hardly be easier and is fully supported by DIGSI 4. The status of the binary inputs can be read individually and the state of the binary outputs can be set individually. The operation of switching elements (circuit-breakers, disconnect devices) can be checked using the switching functions of the bay controller. The analog measured values are represented as wideranging operational measured values. To prevent transmission of information to the control center during maintenance, the bay controller communications can be disabled to prevent unnecessary data from being transmitted. During commissioning, all indications with test marking for test purposes can be connected to a control and protection system.

### **Test operation**

During commissioning, all indications can be passed to an automatic control system for test purposes.





Fig. 5/101 CB switching cycle diagram

### Functions

### Control and automatic functions

### Control

In addition to the protection functions, the SIPROTEC 4 units also support all control and monitoring functions that are required for operating medium-voltage or high-voltage substations.

The main application is reliable control of switching and other processes.

The status of primary equipment or auxiliary devices can be obtained from auxiliary contacts and communicated to the 7SJ64 via binary inputs. Therefore it is possible to detect and indicate both the OPEN and CLOSED position or a fault or intermediate circuit-breaker or auxiliary contact position.

The switchgear or circuit-breaker can be controlled via:

- integrated operator panel
- binary inputs
- substation control and protection system
- DIGSI 4

### Automation / user-defined logic

With integrated logic, the user can set, via a graphic interface (CFC), specific functions for the automation of switchgear or substation. Functions are activated via function keys, binary input or via communication interface.

### Switching authority

Switching authority is determined according to parameters, communication or by key-operated switch (when available). If a source is set to "LOCAL", only local switching operations are possible. The following sequence of switching authority is laid down: "LOCAL"; DIGSI PC program, "REMOTE".

### **Key-operated switch**

7SJ64 units are fitted with key-operated switch function for local/remote changeover and changeover between interlocked switching and test operation.

### Functions

### Command processing

All the functionality of command processing is offered. This includes the processing of single and double commands with or without feedback, sophisticated monitoring of the control hardware and software, checking of the external process, control actions using functions such as runtime monitoring and automatic command termination after output. Here are some typical applications:

- Single and double commands using 1, 1 plus 1 common or 2 trip contacts
- User-definable bay interlocks
- Operating sequences combining several switching operations such as control of circuit-breakers, disconnectors and grounding switches
- Triggering of switching operations, indications or alarm by combination with existing information

### Motor control

The SIPROTEC 7SJ64 with high performance relays is well-suited for direct activation of the circuit-breaker, disconnector and grounding switch operating mechanisms in automated substations.

Interlocking of the individual switching devices takes place with the aid of programmable logic. Additional auxiliary relays can be eliminated. This results in less wiring and engineering effort.

### Assignment of feedback to command

The positions of the circuit-breaker or switching devices and transformer taps are acquired by feedback. These indication inputs are logically assigned to the corresponding command outputs. The unit can therefore distinguish whether the indication change is a consequence of switching operation or whether it is a spontaneous change of state.

### Chatter disable

Chatter disable feature evaluates whether, in a configured period of time, the number of status changes of indication input exceeds a specified figure. If exceeded, the indication input is blocked for a certain period, so that the event list will not record excessive operations.

### Indication filtering and delay

Binary indications can be filtered or delayed.

Filtering serves to suppress brief changes in potential at the indication input. The



Fig. 5/102 Typical wiring for 7SJ642 motor direct control (simplified representation without fuses). Binary output BO6 and BO7 are interlocked so that only one set of contacts are closed at a time.



Fig. 5/103 Example: Single busbar with circuit-breaker and motor-controlled three-position switch





### **Functions**

indication is passed on only if the indication voltage is still present after a set period of time.

In the event of indication delay, there is a wait for a preset time. The information is passed on only if the indication voltage is still present after this time.

### Indication derivation

A further indication (or a command) can be derived from an existing indication. Group indications can also be formed. The volume of information to the system interface can thus be reduced and restricted to the most important signals.

### Measured values

The r.m.s. values are calculated from the acquired current and voltage along with the power factor, frequency, active and reactive power. The following functions are available for measured value processing:

- Currents  $I_{L1}$ ,  $I_{L2}$ ,  $I_{L3}$ ,  $I_{E}$ ,  $I_{EE}$  (67Ns)
- Voltages V<sub>L1</sub>, V<sub>L2</sub>, V<sub>L3</sub>, V<sub>L1L2</sub>, V<sub>L2L3</sub>, V<sub>L3L1</sub>, V<sub>syn</sub>
- Symmetrical components I1, I2, 3I0; V1, V2, V0
- Power Watts, Vars, VA/P, Q, S (P, Q: total and phase selective)
- Power factor (cos  $\varphi$ ), (total and phase selective)
- Frequency
- Energy  $\pm$  kWh,  $\pm$  kVarh, forward and reverse power flow
- Mean as well as minimum and maximum current and voltage values
- Operating hours counter
- Mean operating temperature of overload function
- Limit value monitoring Limit values are monitored using programmable logic in the CFC. Commands can be derived from this limit value indication.
- Zero suppression

In a certain range of very low measured values, the value is set to zero to suppress interference.

### Metered values

For internal metering, the unit can calculate an energy metered value from the measured current and voltage values. If an external meter with a metering pulse output is available, the SIPROTEC 4 unit can obtain and process metering pulses via an indication input.

The metered values can be displayed and passed on to a control center as an accumulation with reset. A distinction is made between forward, reverse, active and reactive energy.

### Switchgear cubicles for high/medium voltage

All units are designed specifically to meet the requirements of high/medium-voltage applications.

In general, no separate measuring instruments (e.g. for current, voltage, frequency measuring transducer ...) or additional control components are necessary.



Fig. 5/105 NX PLUS panel (gas-insulated)

### Communication

### Communication

In terms of communication, the units offer substantial flexibility in the context of connection to industrial and power automation standards. Communication can be extended or added on thanks to modules for retrofitting on which the common protocols run. Therefore, also in the future it will be possible to optimally integrate units into the changing communication infrastructure, for example in Ethernet networks (which will also be used increasingly in the power supply sector in the years to come).

#### Serial front interface

There is a serial RS232 interface on the front of all the units. All of the unit's functions can be set on a PC by means of the DIGSI 4 protection operation program. Commissioning tools and fault analysis are also built into the program and are available through this interface.

#### Rear-mounted interfaces<sup>1)</sup>

A number of communication modules suitable for various applications can be fitted in the rear of the flush-mounting housing. In the flush-mounting housing, the modules can be easily replaced by the user.

The interface modules support the following applications:

• Time synchronization interface

All units feature a permanently integrated electrical time synchronization interface. It can be used to feed timing telegrams in IRIG-B or DCF77 format into the units via time synchronization receivers.

System interface

Communication with a central control system takes place through this interface. Radial or ring type station bus topologies can be configured depending on the chosen interface. Furthermore, the units can exchange data through this interface via Ethernet and IEC 61850 protocol and can also be operated by DIGSI.

Service interface

The service interface was conceived for remote access to a number of protection units via DIGSI. It can be an electrical RS232/RS485 interface. For special applications, a maximum of two temperature monitoring boxes (RTD-box) can be connected to this interface as an alternative.

Additional interface

Up to 2 RTD-boxes can be connected via this interface.

### System interface protocols (retrofittable)

### IEC 61850 protocol

The Ethernet-based IEC 61850 protocol is the worldwide standard for protection and control systems used by power supply corporations. Siemens was the first manufacturer to support this standard. By means of this protocol, information can also be exchanged directly between bay units so as to set up simple masterless systems for bay and system interlocking. Access to the units via the Ethernet bus is also possible with DIGSI. It is also possible to retrieve operating and fault messages and fault recordings via a browser. This Web monitor also provides a few items of unitspecific information in browser windows.

1) For units in panel surface-mounting housings please refer to note on page 5/193.



Fig. 5/106 IEC 60870-5-103: Radial fiber-optic connection



Fig. 5/107 Bus structure for station bus with Ethernet and IEC 61850, fiber-optic ring

### IEC 60870-5-103 protocol

The IEC 60870-5-103 protocol is an international standard for the transmission of protective data and fault recordings. All messages from the unit and also control commands can be transferred by means of published, Siemens-specific extensions to the protocol.

Redundant solutions are also possible. Optionally it is possible to read out and alter individual parameters (only possible with the redundant module).

#### **PROFIBUS DP protocol**

PROFIBUS DP is the most widespread protocol in industrial automation. Via PROFIBUS DP, SIPROTEC units make their information available to a SIMATIC controller or, in the control direction, receive commands from a central SIMATIC. Measured values can also be transferred.

### Communication

### **MODBUS RTU protocol**

This uncomplicated, serial protocol is mainly used in industry and by power supply corporations, and is supported by a number of unit manufacturers. SIPROTEC units function as MODBUS slaves, making their information available to a master or receiving information from it. A timestamped event list is available.

### PROFINET

PROFINET is the ethernet-based successor of PROFIBUS DP and is supported in the variant PROFINET IO. The protocol which is used in industry together with the SIMATIC systems control is realized on the optical and electrical Plus ethernet modules which are delivered since November 2012, All network redundancy procedures which are available for the ethernet modules, such as RSTP, PRP or HSR, are also available for PROFINET. The time synchronization is made via SNTP. The network monitoring is possible via SNMP V2 where special MIB files exist for PROFINET. The LLDP protocol of the device also supports the monitoring of the network topology. Single-point indications, double-point indications, measured and metered values can be transmitted cyclically in the monitoring direction via the protocol and can be selected by the user with DIGSI 4. Important events are also transmitted spontaneously via configurable process alarms. Switching commands can be executed by the system control via the device in the controlling direction. The PROFINET implementation is certified. The device also supports the IEC 61850 protocol as a server on the same ethernet module in addition to the PRO-FINET protocol. Client server connections are possible for the intercommunication between devices, e.g. for transmitting fault records and GOOSE messages.



Fig. 5/108 System solution/communication



Fig. 5/109 Optical Ethernet communication module for IEC 61850 with integrated Ethernet-switch

### DNP 3.0 protocol

Power utilities use the serial DNP 3.0 (Distributed Network Protocol) for the station and network control levels. SIPROTEC units function as DNP slaves, supplying their information to a master system or receiving information from it.

### DNP3 TCP

The ethernet-based TCP variant of the DNP3 protocol is supported with the electrical and optical ethernet module. Two DNP3 TCP clients are supported. Redundant ring structures can be realized for DNP3 TCP with the help of the integrated switch in the module. For instance, a redundant optical ethernet ring can be constructed. Single-point indications, double-point indications, measured and metered values can be confi gured with DIGSI 4 and are transmitted to the DNPi client. Switching commands can be executed in the controlling direction. Fault records of the device are stored in the binary Comtrade format and can be retrieved via the DNP3 file transfer. The time synchronization is performed via the DNP3 TCP client or SNTP. The device can also be integrated into a network monitoring system via the SNMP V2 protocol. Parallel to the DNP3 TCP protocol the IEC 61850 protocol (the device works as a server) and the GOOSE messages of the IEC 61850 are available for the intercommunication between devices.

### System solutions for protection and station control

Together with the SICAM power automation system, SIPROTEC 4 can be used with PROFIBUS DP. Over the low-cost electrical RS485 bus, or interference-free via the optical double ring, the units exchange information with the control system.

Units featuring IEC 60870-5-103 interfaces can be connected to SICAM in parallel via the RS485 bus or radially by fiber-optic link.

### **Typical connections**

Through this interface, the system is open for the connection of units of other manufacturers (see Fig. 5/106).

Because of the standardized interfaces, SIPROTEC units can also be integrated into systems of other manufacturers or in SIMATIC. Electrical RS485 or optical interfaces are available. The optimum physical data transfer medium can be chosen thanks to optoelectrical converters. Thus, the RS485 bus allows low-cost wiring in the cubicles and an interference-free optical connection to the master can be established. For IEC 61850, an interoperable system solution is offered with SICAM PAS. Via the 100 Mbits/s Ethernet bus, the units are linked with PAS electrically or optically to the station PC. The interface is standardized, thus also enabling direct connection of units of other manufacturers to the Ethernet bus. With IEC 61850, how-ever, the units can also be used in other manufacturers' systems (see Fig. 5/107).

### **Typical connections**

#### Connection of current and voltage transformers

#### Standard connection

For grounded networks, the ground current is obtained from the phase currents by the residual current circuit.



Fig. 5/110 Residual current circuit without directional element



Fig. 5/111 Sensitive ground current detection without directional element



Fig. 5/112 Residual current circuit with directional element

5

### **Typical connections**

### Connection for compensated networks

The figure shows the connection of two phase-to-ground voltages and the  $V_{\rm E}$  voltage of the open delta winding and a phase-ground neutral current transformer for the ground current. This connection maintains maximum precision for directional ground-fault detection and must be used in compensated networks. Fig. 5/113 shows sensitive directional ground-fault detection.



Fig. 5/113 Sensitive directional ground-fault detection with directional element for phases



Fig. 5/114 Isolated-neutral or compensated networks



Fig. 5/115 Measuring of the busbar voltage and the outgoing feeder voltage for synchronization

## Connection for isolated-neutral or compensated networks only

If directional ground-fault protection is not used, the connection can be made with only two phase current transformers. Directional phase short-circuit protection can be achieved by using only two primary transformers.

## Connection for the synchronization function

The 3-phase system is connected as reference voltage, i. e. the outgoing voltages as well as a single-phase voltage, in this case a busbar voltage, that has to be synchronized.

### **Typical applications**

Overview of connection types						
Type of network	Function	Current connection	Voltage connection			
(Low-resistance) grounded network	Overcurrent protection phase/ground non-directional	Residual circuit, with 3 phase-current transformers required, phase-balance neutral current transformer possible	-			
(Low-resistance) grounded networks	Sensitive ground-fault protection	Phase-balance neutral current transformers required	-			
Isolated or compensated networks	Overcurrent protection phases non-directional	Residual circuit, with 3 or 2 phase current transformers possible	-			
(Low-resistance) grounded networks	Overcurrent protection phases directional	Residual circuit, with 3 phase-current transformers possible	Phase-to-ground connection or phase-to-phase connection			
Isolated or compensated networks	Overcurrent protection phases directional	Residual circuit, with 3 or 2 phase- current transformers possible	Phase-to-ground connection or phase-to-phase connection			
(Low-resistance) grounded networks	Overcurrent protection ground directional	Residual circuit, with 3 phase-current transformers required, phase-balance neutral current transformers possible	Phase-to-ground connection required			
Isolated networks	Sensitive ground-fault protection	Residual circuit, if ground current > 0.05 $I_N$ on secondary side, otherwise phase-balance neutral current transformers required	3 times phase-to-ground connection or phase-to-ground connection with open delta winding			
Compensated networks	Sensitive ground-fault protection $\cos \varphi$ measurement	Phase-balance neutral current transformers required	Phase-to-ground connection with open delta winding required			

#### **Typical applications**

#### Application examples

### Synchronization function

When two subnetworks must be interconnected, the synchronization function monitors whether the subnetworks are synchronous and can be connected without risk of losing stability.

As shown in Fig. 5/116, load is being fed from a generator to a busbar via a transformer. It is assumed that the frequency difference of the 2 subnetworks is such that the device determines asynchronous system conditions.

The voltages of the busbar and the feeder should be the same when the contacts are made; to ensure this condition the synchronism function must run in the

"synchronous/asynchronous switching" mode. In this mode, the operating time of the CB can be set within the relay.

Differences between angle and frequency can then be calculated by the relay while taking into account the operating time of the CB. From these differences, the unit derives the exact time for issuing the CLOSE command under asynchronous conditions. When the contacts close, the voltages will be in phase.



Fig. 5/116 Measuring of busbar and feeder voltages for synchronization

The vector group of the transformer can be considered by setting parameters. Thus no external circuits for vector group adaptation are required.

This synchronism function can be applied in conjunction with the auto-reclosure function as well as with the control function CLOSE commands (local/remote).

### **Typical applications**

### Connection of circuit-breaker

Undervoltage releases

Undervoltage releases are used for automatic tripping of high-voltage motors.

#### Example:

position.

DC supply voltage of control system fails and manual electric tripping is no longer possible.

Automatic tripping takes place when voltage across the coil drops below the trip limit. In Figure 5/172, tripping occurs due to failure of DC supply voltage, by automatic opening of the live status contact upon failure of the protection unit or by short-circuiting the trip coil in event of a network fault.

In Fig. 5/118 tripping is by failure of auxil-

iary voltage and by interruption of tripping

circuit in the event of network failure. Upon

failure of the protection unit, the tripping

held by internal logic drops back into open

circuit is also interrupted, since contact



Fig. 5/117 Undervoltage release with make contact 50, 51



Fig. 5/118 Undervoltage release with locking contact (trip signal 50 is inverted)

### Typical applications

### Trip circuit supervision (ANSI 74TC)

One or two binary inputs can be used for monitoring the circuit-breaker trip coil including its incoming cables. An alarm signal occurs whenever the circuit is interrupted.

### Lockout (ANSI 86)

All binary outputs can be stored like LEDs and reset using the LED reset key. The lockout state is also stored in the event of supply voltage failure. Reclosure can only occur after the lockout state is reset.

## Reverse-power protection for dual supply (ANSI 32R)

If power is fed to a busbar through two parallel infeeds, then in the event of any fault on one of the infeeds it should be selectively interrupted. This ensures a continued supply to the busbar through the remaining infeed. For this purpose, directional devices are needed which detect a short-circuit current or a power flow from the busbar in the direction of the infeed. The directional overcurrent protection is usually set via the load current. It cannot be used to deactivate low-current faults. Reverse-power protection can be set far below the rated power. This ensures that it also detects power feedback into the line in the event of lowcurrent faults with levels far below the load current. Reverse-power protection is performed via the "flexible protection functions" of the 7SJ64.







Fig. 5/120 Reverse-power protection for dual supply

### **Technical data**

	General unit data		Binary outputs/command	loutputs				
	Measuring circuits		Туре	7SJ640	7SJ641	7SJ642	7SJ645	7SJ647
	System frequency	50 / 60 Hz (settable)	Number (marshallable)	7	15	20	33	48
Ì	Current transformer		Voltage range	DC 24 –	250 V			
1	Rated current I <sub>nom</sub>	1 or 5 A (settable)	Pickup threshold					
	Option: sensitive ground-fault CT	<i>I</i> <sub>EE</sub> < 1.6 A	modifiable by plug-in					
	Power consumption		Jumpers Rickup throshold DC	DC 10 V	,		,	
	at $I_{nom} = 1 \text{ A}$ at $I_{nom} = 5 \text{ A}$ for sensitive ground-fault CT at 1 A	Approx. 0.05 VA per phase Approx. 0.3 VA per phase Approx. 0.05 VA	For rated control voltage	DC 19 V	8/60/110	/ DC 110/	125/220/	250 V
	Overload capability Thermal (effective)	500 A for 1 s 150 A for 10 s	Power consumption energized	0.9 mA for BI 8.	(indepen 19 / 21	dent of o 32; 7 / 20/33	perating v	voltage)
	Dynamic (impulse current)	20 A continuous 250 x I <sub>nom</sub> (half cycle)	Ringry outputs/command		югыт	7120133	40	
	Overload capability if equipped with				751641	751642	761645	751647
	sensitive ground-fault CT		Type	75J640	/5/641	75J642	/5J645	75J647
	Thermal (effective)	300 A for 1 s	command/indication relay	5	13	8	11	21
		100 A for 10 s	Contacts per command/	1 NO / f	orm A			
	Dynamic (impulse current)	750 A (half cycle)	indication relay	11071	011177			
1	Voltage transformer		Live status contact	1 NO / N	IC (jumpe	er) / form	A / B	
	Rated voltage V <sub>nom</sub>	100 V to 225 V	Switching capacity					
	Measuring range	0 V to 200 V	Make	1000 W	/ VA			
	Power consumption at $V_{\text{nom}} = 100 \text{ V}$	< 0.3 VA per phase	Break	30 W / V 25 W at	/A / 40 W	resistive ,	I	
	Overload capability in voltage path		Switching voltage	< DC 25	0 V	1115		
	(phase-neutral voltage)	230 V continuous	Permissible current	5 A cont	tinuous			
1	Auxiliary voltage (via integrated conv	verter)		30 A for	0.5 s ma	king curr	ent,	
	Pated auxiliary voltage V DC	24/48 V 60/125 V 110/250 V		2000 sv	vitching c	ycles		
	Permissible tolerance DC	19-58 V 48-150 V 88-300 V	Power relay (for motor co	ntrol)				
	Ripple voltage,	$\leq 12$ % of rated auxiliary voltage	Туре	7SJ640 7SJ641	7SJ642	7SJ645	7SJ647	
	Power consumption	7SJ640 7SJ641 7SJ645 7SJ647 7SJ642	Number Number of contacts/relay	0	2 (4) 2 NO / f	4 (8) orm A	4 (8)	
	Oujescent Approx.	5 W 5.5 W 6.5 W 7.5 W	Switching capacity					
	Energized Approx.	9 W 12.5 W 15 W 21 W	Make	1000 W	/ VA 250 V /	500 W a	† 74 \/	
	Backup time during loss/short-circuit of auxiliary direct voltage	$\ge$ 50 ms at V > DC 110 V $\ge$ 20 ms at V > DC 24 V	Break	1000 W at 48 V	/ VA 250 V /	500 W a	t 24 V	
	Bated auxiliary voltage Vaux AC	115 V/230 V	Switching voltage	≤ DC 25	0 V			
	Permissible tolerance AC	92 - 32 V/184 - 265 V	Permissible current	5 A cont	tinuous,			
	Power consumption	7SJ640 7SJ641 7SJ645 7SJ647		30 A for	0.5 s			
	·	7SJ642						
	Quiescent Approx.	7 W 9 W 12 W 16 W						
	Backup time during loss/short-circuit of auxiliary alternating voltage	≥ 200 ms						

### **Technical data**

Electrical tests		Radiated electromagnetic	35 V/m; 25 to 1000 MHz;
Specification		interference ANSI/IEEE C37 90 2	amplitude and pulse-modulated
Standards	IEC 60255 ANSI C37.90, C37.90.1, C37.90.2, UL508	Damped wave IEC 60694 / IEC 61000-4-12	2.5 kV (peak value, polarity alternating) 100 kHz, 1 MHz, 10 and 50 MHz,
Insulation tests			$R_{\rm i} = 200 \ \Omega$
Standards	IEC 60255-5; ANSI/IEEE C37.90.0	EMC tests for interference emission	n; type tests
all circuits except for auxiliary voltage and RS485/RS232 and time synchronization	2.5 kV (r.m.s. value), 50/60 Hz	Standard Conducted interferences only auxiliary voltage IEC/CISPR 22	EN 50081-* (generic specification) 150 kHz to 30 MHz Limit class B
Auxiliary voltage	DC 3.5 kV	Radio interference field strength	30 to 1000 MHz Limit class B
Communication ports and time synchronization	AC 500 V	Units with a detached operator panel must be installed in a meta	1
Impulse voltage test (type test) all circuits, except communication ports and time synchronization.	5 kV (peak value); 1.2/50 μs; 0.5 J 3 positive and 3 negative impulses at intervals of 5 s	cubicle to maintain limit class B	
class III		Mechanical stress tests	
EMC tests for interference immunit	y; type tests	Vibration, shock stress and seismic	: vibration
Standards	IEC 60255-6; IEC 60255-22	During operation	
	(product standard)	Standards	IEC 60255-21 and IEC 60068-2
	DIN 57435 Part 303	Vibration	Sinusoidal
High-frequency test IEC 60255-22-1, class III and VDE 0435 Part 303, class III	2.5 kV (peak value); 1 MHz; $\tau$ =15 ms; 400 surges per s; test duration 2 s	IEC 60255-21-1, class 2 IEC 60068-2-6	10 to 60 Hz; $\pm$ 0.075 mm amplitude; 60 to 150 Hz; 1 g acceleration frequency sweep 1 octave/min 20 cycles in 3 perpendicular axes
Electrostatic discharge IEC 60255-22-2 class IV and EN 61000-4-2, class IV	8 kV contact discharge; 15 kV air gap discharge; both polarities; 150 pF; $R_i$ = 330 Ω	Shock IEC 60255-21-2, class 1 IEC 60068-2-27	Semi-sinusoidal Acceleration 5 g, duration 11 ms; 3 shocks in both directions of 3 axes
Irradiation with radio-frequency field, non-modulated IEC 60255-22-3 (Report) class III	10 V/m; 27 to 500 MHz	Seismic vibration IEC 60255-21-3, class 1 IEC 60068-3-3	Sinusoidal 1 to 8 Hz: ± 3.5 mm amplitude (horizontal axis)
Irradiation with radio-frequency field, amplitude-modulated IEC 61000-4-3; class III	10 V/m, 80 to 1000 MHz; AM 80 %; 1 kHz		1 to 8 Hz: $\pm$ 1.5 mm amplitude (vertical axis) 8 to 35 Hz: 1 g acceleration
Irradiation with radio-frequency field, pulse-modulated IEC 61000-4-3/ENV 50204; class III	10 V/m, 900 MHz; repetition rate 200 Hz, on duration 50 %		(horizontal axis) 8 to 35 Hz: 0.5 g acceleration (vertical axis)
Fast transient interference/burst IEC 60255-22-4 and IEC 61000-4-	4 kV; 5/50 ns; 5 kHz; burst length = 15 ms; repetition rate 300 ms; both polarities;	During transportation	1 cycle in 3 perpendicular axes
.,	$R_{\rm i} = 50 \ \Omega$ ; test duration 1 min	Standards	IEC 60255-21 and IEC 60068-2
High-energy surge voltages (Surge) IEC 61000-4-5; class III Auxiliary voltage	From circuit to circuit: 2 kV; 12 $\Omega$ ; 9 $\mu$ F across contacts: 1 kV; 2 $\Omega$ ;18 $\mu$ F	Vibration IEC 60255-21-1, class 2 IEC 60068-2-6	Sinusoidal 5 to 8 Hz: $\pm$ 7.5 mm amplitude; 8 to 150 Hz; 2 g acceleration, frequency sweep 1 octave/min 20 cycles in 3 perpendicular axes
Binary inputs/outputs	From circuit to circuit: 2 kV; 42 $\Omega$ ; 0.5 $\mu F$ across contacts: 1 kV; 42 $\Omega$ ; 0.5 $\mu F$	Shock IEC 60255-21-2, Class 1	Semi-sinusoidal Acceleration 15 $g$ , duration 11 ms
Line-conducted HF, amplitude-modulated IEC 61000-4-6, class III	10 V; 150 kHz to 80 MHz; AM 80 %; 1 kHz	IEC 60068-2-27 Continuous shock IEC 60255-21-2 class 1	3 shocks in both directions of 3 axes Semi-sinusoidal
Power frequency magnetic field IEC 61000-4-8, class IV IEC 60255-6	30 A/m; 50 Hz, continuous 300 A/m; 50 Hz, 3 s 0.5 mT, 50 Hz	IEC 60068-2-29	1000 shocks in both directions of 3 axes
Oscillatory surge withstand capability ANSI/IEEE C37.90.1	2.5 to 3 kV (peak value), 1 to 1.5 MHz damped wave; 50 surges per s; duration 2 s, $R_i = 150$ to 200 $\Omega$		
Fast transient surge withstand capability ANSI/IEEE C37.90.1	4 to 5 kV; 10/150 ns; 50 surges per s both polarities; duration 2 s, $R_{\rm i}$ = 80 $\Omega$		

5

### **Technical data**

Climatic stress tests				
Temperatures				
Type-tested acc. to IEC 60068-2-1 and -2, test Bd, for 16 h	-25 °C to +8	-25 °C to +85 °C /-13 °F to +185 °F		
Temporarily permissible operating temperature, tested for 96 h	-20 °C to +7	0 °C / -4 °F to	+158 °F	
Recommended permanent operating temperature acc. to IEC 60255-6 (Legibility of display may be impaired above +55 °C /+131 °F)	-5 °C to +55	°C / +25 °F to	o +131 °F	
<ul> <li>Limiting temperature during permanent storage</li> </ul>	-25 °C to +5	5 °C / -13 °F t	to +131 °F	
<ul> <li>Limiting temperature during transport</li> </ul>	-25 °C to +7	0 °C / -13 °F t	to +158 °F	
Humidity				
Permissible humidity It is recommended to arrange the units in such a way that they are not exposed to direct sunlight or pronounced temperature changes that could cause condensation.	Annual average 75 % relative humi- e dity; on 56 days a year up to 95 % relative humidity; condensation not permissible! s			
Unit design				
Туре	7SJ640 7SJ642	7SJ641	7SJ645 7SJ647	
Housing	7XP20			
Dimensions	See dimens this catalog	ion drawings	, part 14 of	
Weight in kg	Housing width ⅓	Housing width ½	Housing width ¼	
Surface-mounting housing Flush-mounting housing Housing for detached operator	8 5	11 6	15 10	
operator panel Detached operator panel	-	8 2.5	12 2.5	
Degree of protection acc. to EN 60529 Surface-mounting housing Flush-mounting housing Operator safety	IP 51 Front: IP 51 IP 2x with c	, rear: IP 20; over		

Futher information can be found in the current manual at: www.siemens.com/siprotec

### Selection and ordering data

Description	Order No.
7SJ64 multifunction protection relay with synchronization	75J64
Housing, binary inputs and outputs	
Housing $\frac{1}{3}$ 19", 7 BI, 5 BO, 1 live status contact, text display 4 x 20 character (only for 7SJ640) 9th position only with: <b>B. D. E</b>	0
Housing ½ 19", 15 BI, 13 BO (1 NO/NC or 1a/b contact), 1 live status contact, graphic display	
Housing ½ 19", 20 BI, 8 BO, 2 power relays (4 contacts), 1 live status contact, graphic display	2 See next page
Housing ½ 19", 33 BI, 11 BO, 4 power relays (8 contacts), 1 live status contact, graphic display	5
Housing ½ 19", 48 BI, 21 BO, 4 power relays (8 contacts), 1 live status contact, graphic display	7
Measuring inputs $(4 \times V, 4 \times I)$	
$I_{\text{ph}} = 1 \text{ A}^{1}, I_{\text{e}} = 1 \text{ A}^{1}$ (min. = 0.05 A) Position 15 only with <b>A</b> , <b>C</b> , <b>E</b> , <b>G</b>	1
$I_{\rm ph}$ = 1 A <sup>1)</sup> , $I_{\rm e}$ = sensitive (min. = 0.001 A) Position 15 only with <b>B, D, F, H</b>	2
I <sub>ph</sub> = 5 A <sup>1)</sup> , I <sub>e</sub> = 5 A <sup>1)</sup> (min. = 0.25 A) Position 15 only with <b>A, C, E, G</b>	5
I <sub>ph</sub> = 5 A <sup>1)</sup> , I <sub>e</sub> = sensitive (min. = 0.001 A) Position 15 only with <b>B, D, F, H</b>	6
I <sub>ph</sub> = 5 A <sup>1)</sup> , I <sub>e</sub> = 1 A <sup>1)</sup> (min. = 0.05 A) Position 15 only with <b>A, C, E,G</b>	7
Rated auxiliary voltage (power supply, binary inputs)	
DC 24 to 48 V, threshold binary input DC 19 V $^{3)}$	2
DC 60 to 125 V <sup>2)</sup> , threshold binary input DC19 V <sup>3)</sup>	4
DC 110 to 250 V $^{2)}$ , AC 115 to 230 V, threshold binary input DC 88 V $^{3)}$	5
Unit version	
Surface-mounting housing, plug-in terminals, detached operator panel, panel mounting in low-voltage housing	A
Surface-mounting housing, 2-tier terminals on top/bottom	В
Surface-mounting housing, screw-type terminals (direct connection/ring-type cable lugs), detached operator panel, panel mounting in low-voltage housing	с
Flush-mounting housing, plug-in terminals (2/3 pin connector)	D
Flush-mounting housing, screw-type terminals (direct connection/ring-type cable lugs)	E
Surface-mounting housing, screw-type terminals (direct connection/ring-type cable lugs), without operator panel, panel mounting in low-voltage housingg	F
Surface-mounting housing, plug-in terminals, without operator panel, panel mounting in low-voltage housing	G
Region-specific default settings/function versions and language settings	
Region DE, 50 Hz, IEC, language: German (language selectable)	A
Region World, 50/60 Hz, IEC/ANSI, language: English (GB) (language selectable)	В
Region US, 60 Hz, ANSI, language: English (US) (language selectable)	С
Region FR, 50/60 Hz, IEC/ANSI, language: French (language selectable)	D
Region World, 50/60 Hz, IEC/ANSI, language: Spanish (language selectable)	E
Kegion II, 50/60 Hz, IEC/ANSI, language: Italian (language selectable)	F
Region RU, 50/60 Hz, IEC/ANSI, language: Russian(language can be changed)	G

- 1) Rated current can be selected by means of jumpers.
- 2) Transition between the two auxiliary voltage ranges can be selected by means of jumpers.
- 3) The binary input thresholds can be selected per binary input by means of jumpers.

### Selection and ordering data

Description	Order No.	Order code
7SJ64 multifunction protection relay with synchronization	7SJ64	
System interface (on rear of unit, Port B)		
No system interface	0	
IEC 60870-5-103 protocol, RS232	1	See
IEC 60870-5-103 protocol, RS485	2	pages
IEC 60870-5-103 protocol, 820 nm fiber, ST connector	3	
PROFIBUS DP Slave, RS485	9	LOA
PROFIBUS DP Slave, 820 nm wavelength, double ring, ST connector <sup>1)</sup>	9	L O B
MODBUS, RS485	9	L 0 D
MODBUS, 820 nm wavelength, ST connector <sup>2)</sup>	9	L 0 E
DNP 3.0, RS485	9	L 0 G
DNP 3.0, 820 nm wavelength, ST connector <sup>2)</sup>	9	L 0 H
IEC 60870-5-103 protocol, redundant, RS485, RJ45 connector <sup>2)</sup>	9	L 0 P
IEC 61850, 100 Mbit Ethernet, electrical, double, RJ45 connector (EN 100)	9	L O R
IEC 61850, 100 Mbit Ethernet, optical, double, LC connector (EN 100) <sup>2)</sup>	9	L 0 S
DNP3 TCP + IEC 61850, 100Mbit Eth, electrical, double, RJ45 connector <sup>4)</sup>	9	L 2 R
DNP3 TCP + IEC 61850, 100Mbit Eth, optical, double, LC connector <sup>4)</sup>	9	L 2 5
PROFINET + IEC 61850, 100Mbit Eth, electrical, double, RJ45 connector <sup>4)</sup>	9	L 3 R
PROFINET + IEC 61850, 100Mbit Eth, optical, double, LC connector <sup>4)</sup>	9	L 3 S
Only Port C (service interface)		
DIGSI 4/modem, electrical RS232	1	
DIGSI 4/modem/RTD-box <sup>3)</sup> , electrical RS485	2	
Port C and D (service and additional interface)	9	M
Port C (service interface)		
DIGSI 4/modem, electrical RS232		1
DIGSI 4/modem/RTD-box <sup>3)</sup> , electrical RS485		2
PortD(additional interface)		
RTD-box <sup>3)</sup> , 820 nm fiber, ST connector <sup>5)</sup>		A
RTD-box <sup>3)</sup> , electrical RS485		F
Measuring/fault recording		
Fault recording		1
Slave pointer,mean values, min/max values, fault recording		3

 Not with position 9 = "B"; if 9 = "B", please order 7SJ6 unit with RS485 port and separate fiber-optic converters. For single ring, please order converter 6GK1502-2CB10, not available with position 9 = "B".
 For double ring, please order converter 6GK1502-3CB10, not available with position 9 = "B".
 The converter requires a AC 24 V power supply (e.g. power supply 7XV5810-0BA00). 2) Not available with position 9 = "B".

3) Temperature monitoring box 7XV5662-□AD10, refer to "Accessories".

4) Available with V4.9

5) When using the temperature monitoring box at an optical interface, the additional RS485 fiber-optic converter 7XV5650-0 A00 is required.

### Selection and ordering data

Description		Order No. Order c
7SJ64 multifunction protect	on relay with synchronization	75J64
Designation Basic version	ANSI No.Description Control50/51Overcurrent protection $I>$ , $I>>$ , $I>>$ , $I_p$ 50N/51NGround-fault protection $I_E>$ , $I_E>>$ , $I_E>>$ , $I_{Ep}$ 50N/51NInsensitive ground-fault protection through IEE function: $I_{EE}>$ , $I_{EE}>>$ , $I_{EEp}^{-1}$ 50/50NFlexible protection functions (index quantities derived from current): Additional time-overcurrent 	
■ V, P, f	27/59 Under-/overvoltage 810/U Under-/overfrequency 27/Q Undervoltage-controlled reactive power protection <sup>3)</sup> 27/47/59(N) Flexible protection (index quantities derived from 32/55/81R current and voltages): Voltage, power, p.f., rate-of-frequency-change protection	FE
■ IEF <i>V</i> , <i>P</i> , <i>f</i>	<ul> <li>27/59 Under-lovervoltage</li> <li>81O/U Under-loverfrequency</li> <li>27/Q Undervoltage-controlled reactive power protection <sup>3)</sup></li> <li>27/47/59(N) Flexible protection (index quantities derived from</li> <li>32/55/81R currentandvoltages):Voltage, power, p.f., rate-of-frequency-change protection Intermittent ground fault</li> </ul>	P E
Dir	67/67N Direction determination for overcurrent, phases and ground	FC
Dir <i>V, P, f</i>	<ul> <li>67/67N Direction determination for overcurrent, phases and ground</li> <li>27/59 Under-/overvoltage</li> <li>810/U Under-/overfrequency</li> <li>27/Q Undervoltage-controlled reactive power protection <sup>3)</sup></li> <li>27/47/59(N) Flexible protection (index quantities derived from</li> <li>32/55/81R current and voltages): Voltage, power, p.f., rate-of-frequency-change protection</li> </ul>	F G
Dir V,P,f IEF	<ul> <li>67/67N Direction determination for overcurrent, phases and ground Intermittent ground fault protection</li> <li>27/59 Under-/overvoltage</li> <li>81U/O Under-/overfrequency</li> <li>27/Q Undervoltage-controlled reactive power protection <sup>3)</sup></li> <li>27/47/59(N) Flexible protection functions (quantities derived from current &amp; voltages)</li> <li>32/55/81R Voltage-/power-/p.f/rate of freq. change-protection Intermittent ground-fault</li> </ul>	PG
Dir IEF	67/67N Direction determination for overcurrent, phases and ground Intermittent ground fault	РС
Sens.ground-f.det. Motor Dir V,P,f REF	<ul> <li>67/67N Direction determination for overcurrent, phases and ground</li> <li>67Ns Directional sensitive ground-fault detection</li> <li>67Ns Directional intermittent ground fault protection <sup>3)</sup></li> <li>87N High-impedance restricted ground fault</li> </ul>	F D 2)

Continued on next page

Basic version included

Dir

- V, P, f = Voltage, power, frequency protection = Directional overcurrent protection
- 1) Only with insensitive ground-current transformer when position 7 = **1**, **5**, **7**.
- 2) For isolated/compensated networks only with sensitive ground-current transformer when position 7 = 2, 6.
- IEF = Intermittent ground fault
- 3) available with V4.9

## Selection and ordering data

Description			Order No.	Order code
7SJ64 multifunction protec	tion relay w	ith synchronization	7SJ64	
Designation Basic version	ANSI No. 50/51 50N/51N 50/50N 51 V 49 46 37 47 59N/64 50BF 74TC 86	Description Control Overcurrent protection $I_>$ , $I_>>$ , $I_>>$ , $I_p$ Ground-fault protection $I_E>$ , $I_E>>$ , $I_E>>$ , $I_{Ep}$ Insensitive ground-fault protection via IEE function: $I_{EE}>$ , $I_{EE}>$ , $I_{EE}^{-10}$ Flexible protection functions (index quantities derived from current): Additional time-overcurrent protection stages $I_2>$ , $I_{P}>>>$ , $I_{E}>>>>$ Voltage-dependent inverse-time overcurrent protection Overload protection (with 2 time constants) Phase balance current protection (negative-sequence protection) Undercurrent monitoring Phase sequence Displacement volt Breaker failure protection Trip circuit supervision 4 setting groups, cold-load pickup Inrush blocking Lockout		
Sens.ground-f.det. Motor Dir V,P,f REF	67Ns 67Ns 87N 27/59 81O/U 27/Q 27/47/59(N 32/55/81R	Directional sensitive ground-fault detection Directional intermittent ground fault protection <sup>3)</sup> High-impedance restricted ground fault Under-/overvoltage Under-/overfrequency Undervoltage-controlled reactive power protection <sup>3)</sup> ) Flexible protection (index quantities derived from current and voltages): Voltage, power, p.f., rate-of-frequency-change protection		F F <sup>2)</sup>
Sens.ground-f.det. Motor IEF Dir V,P,f REF	67/67N 67Ns 67Ns	Directional sensitive ground-fault detection, phases and ground Directional sensitive ground-fault detection Directional intermittent ground fault protection <sup>3)</sup>		
	87N	High-impedance restricted ground fault Intermittent ground fault		P D <sup>2)</sup>
Sens.ground-f.det. Motor Dir V,P,f REF	67Ns 67Ns 87N	Directional sensitive ground-fault detection Directional intermittent ground fault protection <sup>3)</sup> High-impedance restricted ground fault		F B <sup>2)</sup>
Sens.ground-f.det. Motor Dir V,P,f REF	67Ns 67Ns 87N 48/14 66/86 51M 27/59 810/U 27/Q 27/47/59(N 32/55/81R	Directional sensitive ground-fault detection Directional intermittent ground fault protection <sup>3)</sup> High-impedance restricted ground fault Starting time supervision, locked rotor Restart inhibit Load jam protection, motor statistics Under-/overvoltage Under-/overfrequency Undervoltage-controlled reactive power protection <sup>3)</sup> ) Flexible protection (index quantities derived from current and voltages): Voltage, power, p.f., rate-of-frequency-change protection		H F <sup>2)</sup>
Sens.ground-f.det. Motor Dir V,P,f REF	67/67N 67Ns 67Ns 87N 48/14 66/86 51M 27/59 81O/U 27/Q 27/47/59(N 32/55/81R	Direction determination for overcurrent, phases and ground Directional sensitive ground-fault detection Directional intermittent ground fault protection <sup>3)</sup> High-impedance restricted ground fault Starting time supervision, locked rotor Restart inhibit Load jam protection, motor statistics Under-/overvoltage Under-/overfrequency Undervoltage-controlled reactive power protection <sup>3)</sup> ) Flexible protection (index quantities derived from current and voltages): Voltage, power, p.f., rate-of-frequency-change protection		н н <sup>2)</sup>
Basic version included V, P, f = Voltage, power, freq Dir = Directional overcurre IEF = Intermittent ground	uency protec ent protection fault	<ol> <li>Only with insensitive ground-current transformer w</li> <li>For isolated/compensated networks only with sensitive transformer when position 7 = 2, 6.</li> <li>available with V4.9</li> </ol>	hen position 7 = <b>1</b> , <b>5</b> , <b>7</b> . tive ground-current	Continued on next page

### Selection and ordering data

Description			Order No.	Order code
7SJ64 multifunction protec	tion relay wi	th synchronization	7SJ64	
Designation	ANSI No.	Description		
Basic version	50/51 50N/51N 50N/51N 50/50N 51 V 49 46 37 47 59N/64 50BF 74TC 86	Control Overcurrent protection $I_>$ , $I_>>$ , $I_>>$ , $I_p$ Ground-fault protection $I_E>$ , $I_E>$ , $I_E>>$ , $I_Ep$ Insensitive ground-fault protection via IEE function: $I_{EE>}$ , $I_{EE>}$ , $I_{EEp}^{1)$ Flexible protection functions (index quantities derived from current): Additional time-overcurrent protection stages $I_2>$ , $I_{P>>>>}$ , $I_{E>>>>}$ Voltage-dependent inverse-time overcurrent protection Overload protection (with 2 time constants) Phase balance current protection (negative-sequence protection) Undercurrent monitoring Phase sequence Displacement voltage Breaker failure protection Trip circuit supervision 4 setting groups, cold-load pickup Inrush blocking Lockout		
Sens.ground-f.det. Motor Dir V,P,f REF	67/67N 67Ns 67Ns 87N 48/14 66/86 51M 27/59 81O/U 27/Q 27/47/59(N 32/55/81R	Direction determination for overcurrent, phases and ground Directional sensitive ground-fault detection Directional intermittent ground fault protection <sup>3</sup> ) High-impedance restricted ground fault Intermittent ground fault Starting time supervision, locked rotor Restart inhibit Load jam protection, motor statistics Undervoltage/overvoltage Underfrequency/overfrequency Undervoltage-controlled reactive power protection <sup>3</sup> ) Flexible protection (index quantities derived from current and voltages): Voltage, power, p.f., rate-of-frequency-change protection	R H	2)
Motor V, P, f Dir	67/67N 48/14 66/86 51M 27/59 81O/U 27/Q 27/47/59(N 32/55/81R	Direction determination for overcurrent, phases and ground Starting time supervision, locked rotor Restart inhibit Load jam protection, motor statistics Under-/overvoltage Under-/overfrequency Undervoltage-controlled reactive power protection <sup>3)</sup> Flexible protection (index quantities derived from current and voltages): Voltage, power, p.f., rate-of-frequency-change protection	не	
Motor	48/14 66/86 51M	Starting time supervision, locked rotor Restart inhibit Load jam protection, motor statistics	на	
ARC, fault locator, synchroniz ATEX100 Certification For protection of explosion-p	zation Without 79 21FL 79, 21FL 25 25, 79,21FL	With auto-reclosure With fault locator With auto-reclosure, with fault locator With synchronization With synchronization, auto-reclosure, fault locator ors (increased-safety type of protection "e")		0 1 2 3 4 7 z x 9 9 <sup>2</sup> )

Basic version included

1) Only with insensitive ground-current transformer when position 7 = 1, 5, 7.

2) This variantmight be supplied with a previous firmware version.

*V*, *P*, *f* = Voltage, power, frequency protection Dir = Directional overcurrent protection

3) available with V4.9

## Selection and ordering data

Accessories	Description	Order No.
	Temperature monitoring box	
	AC/DC 24 to 60 V	7XV5662-2AD10
	AC/DC 90 to 240 V	7XV5662-5AD10
	Varistor/VoltageArrester	
	Voltage arrester for high-impedance REF protection 125 Vrms; 600 A; 1S/S 256	C53207-A401-D76-1
	240 Vrms; 600 A; 1S/S 1088	C53207-A401-D77-1
	Connecting cable	
	Cable between PC/notebook (9-pin con.) and protection unit (9-pin connector) (contained in DIGSI 4, but can be ordered additionally)	7XV5100-4
	Cable between temperature monitoring box and SIPROTEC 4 unit	
	- length 5 m/16.4 ft	7XV5103-7AA05
	- length 25 m/82 ft	7XV5103-7AA25
	- length 50 m/164 ft	7XV5103-7AA50
	Manual for 7SJ64	
	English /German	C53000-G1100-C147-x <sup>1)</sup>

1) x = please inquire for latest edition (exact Order No.).

Accessories		Description	Order No.	Size of package	Supplier
		Terminal safety cover			
	b.ep.	Voltage/current terminal 18-pole/12-pole	C73334-A1-C31-1	1	Siemens
		Voltage/current terminal 12-pole/8-pole	C73334-A1-C32-1	1	Siemens
	P228	Connector 2-pin	C73334-A1-C35-1	1	Siemens
Mounting rail	LS	Connector 3-pin	C73334-A1-C36-1	1	Siemens
	sda	Crimp connector CI2 0.5 to 1 mm <sup>2</sup>	0-827039-1	4000 taped on reel	1)
SP2090-afp.eps		Crimp connector CI2 0.5 to 1 mm <sup>2</sup>	0-827396-1	1	1)
	-afp.	Crimp connector: Type III+ 0.75 to 1.5 mm <sup>2</sup>	0-163084-2	1	1)
	LSP2091	Crimp connector: Type III+ 0.75 to 1.5 mm <sup>2</sup>	0-163083-7	4000 taped on reel	1)
2-pin connector	3-pin connector	Crimping tool for Type III+	0-539635-1	1	1)
		and matching female	0-539668-2	1	1)
		Crimping tool for CI2	0-734372-1	1	1)
s s	Ŵ	and matching female	1-734387-1	1	1)
A O H	fp.ep	Short-circuit links			
093-s	92-a	for current terminals	C73334-A1-C33-1	1	Siemens
LSP2(	LSP2(	for other terminals	C73334-A1-C34-1	1	Siemens
Short-circuit links for current terminals	Short-circuit links for current terminals	Mounting rail for 19" rack	C73165-A63-D200-1	1	Siemens

1) Your local Siemens representative can inform you on local suppliers.

### **Connection diagram**



\*) For pinout of communication ports see part 14 of this catalog. For the allocation of the terminals of the panel surface-mounting version refer to the manual (http://www.siemens.com/siprotec).

### **Connection diagram**

Ho	ousing for pa	anel surface mounting	<u>g</u>					_		
	ł	Housing for surface n	nounting/flush	mounting					7SJ641x-x E	3 xxx-xxxx
25	Q1		7SJ641	BO1				- 74	/SJ641X-X /	xxx-xxxx ;
50				BO2	•	+ R2 -		99		)
24		$I_{L2}$		BO3	•	- R3-		- 73	F	
49		•				- R4 -		98	0	ì
		I_1		BO4	┌───	R5		97		
22		_•~~_ 3 <i>I I</i> _				R6		72		
47		010/ 1E		BO5				- 96		
20		$-V_{L1}$			<u> </u>	TT K8 L				
19						; <del> </del> КЗ -		90		
44	R18			BO6	13 Z	<u> </u> К4		65		
45	<u>  R16</u>	• 000 1/		BO7	_ <b>_</b>	- Кб-		64		
		$V_4$		BO8	•	<u>+</u> [K7]-		88		
40				BO9	↓	<u>- K8</u>		63		
						<u>+                                    </u>		89		
				BO10	┌ `	+ кэ-		87		
56				DO11				62		
55	F8			BOLL				86		
54	F9			BO12						
83				0012		, <u>скіз</u> Н К14 –		60		
95				BO13	_ <b>_</b>	K15		84		
						- <u>K16</u> -		- 59		
69	B12					1				
43	——[K17]—			Live status	ĬŽ	E3 -		51		
18	K18			contact		; <u> </u>		52		
42	[]1]									
				Power				15		
		BI10		supply	=	F2 -		16		
40		BI11								
		BI12		Addition	al		D		*)	
				Interface	9			1		
39				Service		iг		ļ	* \	
				interface	•	;┤丿_	. С		)	
						0				
				System		i d b	В		*)	
				interface	e –	Hoto		l		
36							-	ļ		
	<u></u>			Time		47	А		*)	
				synchro	nization				7	
i	i			Forth		÷ ÷		26		
				hous	ing wall 🗄			(Eart	hing	
	ĺ					j		lient	iiiidl)	
	r I							n.eps		
	$\square$	Front	Operator	Earth at	-	₩±		pgpe		
i i	5	port	panel	rear of	housing 🔄			817-		
_	ا 					.'		LSA2		

\*) For pinout of communication ports see part 14 of this catalog. For the allocation of the terminals of the panel surface-mounting version refer to the manual (http://www.siemens.com/siprotec).



### **Connection diagram**

Ho	ousing for pa	nel surface mounting	g				7SJ642x-x	B xxx-xxxx
i i	1	Housing for surface n	nounting/flush	mounting			75 16/12/	Λ ννν-νννν
25	01		7SJ642	B01		-74	/ 550427-7 /	C
50				BO2		- 99		D
24		$I_{L2}$		воз		- 73		F
49		• m r				- 98		G
				B04		97		
48		• 000 21 1				- 72		
				B05		- 96		
20						- 71		
19					$-\frac{1}{1}$ $(-)$ $(+)$	- 12		
44	R18					37		
45	R16			BO6	<u> </u>	-11		
21		$- V_{4}$			1)	i and		
46						- <u>36</u>		
58	F5	— — ВI1			1	201		
57	F6					- 38		
56					(K17]_1)	13		
55				BO10 -		18		
54	F9			B011				
83	F10					42		
95				B012	J11	- 14		
						- 39		
94					_			
69				live status		51		
				contact 3_2	• F4	- 52		
65								
64				Power	+ ; F1	- 15		
63	К4			supply =	- F2 -	-16		
91	— К6							
90	K7	— <b>BI</b> 13		A statistica stati		i .	*)	
89				interface	-Hor -	ł	,	
88		BI15		Service			*)	
62				interface			/	
02								
61				System	БЫв		*)	
60	<u> </u>			interface	Holfol	1		
86	<u>K13</u>							
85	—— <u>K14</u>			Time		i .	*)	
84	K15			synchronization		ł	)	
59	K16					26		
				Earth at		Eart	thina	
	1			rear of housing 🕞		term	nina <b>l</b> )	
	l					sc		
	_		7	_		en ep		
	ΓĽ	Front	Operator	Earth at		-pdbq-		
	$\square$	panel	panel	rear of housing 😇	/	2816		
	ا 					LSA.		

5

\*) For pinout of communication ports see part 14 of this catalog. For the allocation of the terminals of the panel surface-mounting version refer to the manual (http://www.siemens.com/siprotec). 1) Power relays are intended to directly control motorized switches. The power relays are interlocked so only one relay of each pair can close at a time, in order to avoid shorting out the power supply. The power relay pairs are BO6/BO7, BO8/BO9. If used for protection purposes only one binary output of a pair can be used.

### **Connection diagram**

F	Housing for pa	anel surface	e mounting					-	70 1045			
-	I	Housing for	surface m	ounting/f <b>l</b> ush	mounting		-14		7SJ645x-x E	3 XXX-XXXX		
50	01	<u>.</u>	$I_{L1}$	7SJ645	BO1			149	/SJ645x-x /	A XXX-XXXX C		
100	02		J		BO2		-+- R2	199	[	)		
49		_• • • •	$I_{L2}$		BO3	→		- 148	F			
199			- 1					198	(	ć		
98			] <sup>1</sup> L3		BO4			- 197				
47		_•m_	1 3L L-					147				
97	08		J OLO, LE		BO2			146				
45	R15		$V_{L1}$		_			140				
44		_•/ T L	$\bullet V_{L2}$				$-12^{(+)1)}$	- 69				
94			V <sub>L3</sub>		BO6	↓ 1 →		- 18				
46		m_	- - V		+	+ $+$ $+$	1)	ĺ				
96			J <sup>v</sup> <sub>4</sub>		во7 🕂	╪┲┎┙┝╴	- <u> </u>	68				
108	F5		1 BI1				1					
107			• BI2		RO8							
106	F7		BI3		BO9 L			20				
105			BIA		800							
					BO10			- 23				
158	F10		DID		BO11	↓	<u></u>	_ 22				
195	R9 H		1 BI6					- 72				
145			]		BO12							
194		$-\Box$	ן BI7									
144	<u>R12</u>		]		Г		-+ N1 $(+)$ 1)	34				
125	<u>K1</u>		BI8		DO10		+ N2 $(1, 1)$	84				
124	K2		• B <b>I</b> 9		BOI3			- 33				
123	K3		• B <b>I</b> 10		B014	╞╌╢┝		- 83				
122	<u>K4</u>		• BI11		2011							
175	<u></u>		BI12		BO15			85				
174	K7		• B <b>I</b> 13		<b>PO10</b>		   []   []					
173	K8		BI14		BO10 -		+ (P1/) -	<u> </u>				
172	К9		BI15		BO17	_ \		40				
171	K5		]		BO18			- 39				
121			BI16					- 89				
120			• BI17		BO19		- <u>+ [N11]</u>	- 36				
			• B <b>I</b> 18				<u> N12</u>	86				
			• B <b>I</b> 19				1 i					
169	K14				Live status	3 2	F3	101				
118	K15				contact		• <u>F4</u>	102				
140	P1		1 BI21		Power		. ; F1	37				
139	P2	-ī7-	BI22		supply	= (~) <u>-</u>		38				
138	P3		BI23									
137	P4		BI24		Additio	nal	¦Ы р		*)			
190	P6 ]		• B 25		interfac	e	$+ \delta l$					
189			BI26									
			B127		Service		Ц] с	Ì	*)			
100							1 L D			*) For pipou	t of communic	ation ports see
106			BI28						*)	part 14 o	f this catalog.	ation poins see
136	P10		1 BI29		System		Hype P		1	For the al	location of the	terminals of
135			• BI30							the panel	surface-mount	ting version
134	P12		• B <b>I</b> 31		Time				*)	refer to th	ne manual	m/sinrotac)
185	P13		• BI32		synchro	onization			1	(Inttp://ww	www.siemens.co	alte direct
184	P14		]					51		(ontrol m	ays are intende	e to directly
183	P15		B <b>I</b> 33		Earth a rear of	housing (+)		(Ear	thing	relays are	interlocked so	only one relav
133	P16		]				_	tern	ninal)	of each p	air can close at	a time, in orde
								,eps		to avoid s	horting out the	power supply.
	$\square$	Front		Operator	Earth a	nt 🕂	+l÷l	ogper		I he powe	RO13/RO14 P	e BO6/BO7,
		pane		panel	rear of	housing 🔄		8154		If used fo	r protection pu	rposes only one
	ا 						_'	LSA2		binary ou	tput of a pair c	an be used.

Fig. 5/124 7SJ645 connection diagram

- of this catalog. allocation of the terminals of el surface-mounting version the manual www.siemens.com/siprotec). relays are intended to directly
- motorized switches. The power re interlocked so only one relay pair can close at a time, in order I shorting out the power supply. wer relay pairs are BO6/BO7, 09, BO13/BO14, BO15/BO16. for protection purposes only one output of a pair can be used.

### **Connection diagram**

ŀ	Housing for p	anel surface	e mounting						70.1047
		Housing for	r surface and	flush mountin	g		-		/SJ64/x-x B xxx-xxxx
50	Q1	$\vdash \cdots$	ן <i>I</i> L1	7SJ647	BO1 r		- R1	149	C
100	Q2		1		BO2		R2	199	D
49	03				BO3		- R3	148	F
48	05	L.m	- - L -		l	~	R4	198	G
98	Q6	   	1 <sup>2</sup> L3		BO4 [		R5	197	
47	Q7	<b>↓.</b>	1 3 <i>I₀, I</i> ₌		DOF	<u> </u>	- <u>R6</u>		
97	Q8		J 0. L		в05 [		- B8	146	
45	R15						- J1 (-) 1)	- 19	
44		L.m.	$V_{L2}$		1		- <u>J2</u> (+)1)	- 69	
94		· · ·	VL3		BO6			18	
46		L.m	ר V <sub>4</sub>				1)		
96	R14				во7		J4	- 68	
108	F5	-2-	ן BI1				- K18 <sup>1)</sup>	70	
107	F6	$\vdash \Box$	• BI2		B08	i			
106	F7	i-Z-	e Bl3				- <u>K17</u> <sup>1)</sup>	20	
105	F8	-	• B <b>I</b> 4		B03 [				
104	F9	$+\Box$	• BI5		BO10			- 23	
158	F10				BOII				
195		$\vdash \square$	BI6		BO12 r	_	J8	$\frac{72}{21}$	
145	R10				0012		-J12	- 71	
14		, TZF	] 61/				– N1 – 1)	34_]	
125	K1	$\vdash \square$	1 BI8		1		- <u>N2</u> (+) 1)	- 84	
124	К2		• BI9		B013	┝──┤╇──┤	- N3 <sup>1)</sup>	- 33	
123	K3		• BI10				1)		
122	K4		• BI11		B014		N4 - 17	83	
175	К6		• BI12		1		1)	85	
174	 		• BI13		BO15				
173	K8		• BI14				- P17 <sup>1)</sup>	- 35	
172	K0		DI1E		RO 10 [				
172	K5				BO17		N7	40	
121	K10	- - -	1 BI16		BO18		- <u>N9</u>	39	
120	К11		• BI17		BO19	_	N8	<u> </u>	
119	K12	$\vdash$	• BI18		DOID		-N12	- 86	
170	K13		• BI19		в020 <sub>Г</sub>		M1	132	
169	K14				BO21		M2	182	
168	K15	-	BI20				- <u>M3</u>	181	
118	K16		]		BO24			130	
140	P1		BI21		B025		- M6		
139	P2		• BI22		BO22 ſ			179	
138	P3		• BI23		BO23		M8	178	
137	P4	i	• BI24		BO26		- M9	129	
190	P6		• BI25		BO27		- <u>M10</u>	128	
189	P7		• BI26		B∪38.			12/	
188	P8		• BI27		BO29		-M14	- 176	
187	P9	⊨∠-	• BI28		[		M13	- 177	
186	P5								
136	P10		BI29						
135	[P11]		• BI30						
134	P12		• BI31			1			
185	<u>[P13</u>	; - LF	• BI32					so	1) Power relays are intended to directly
184	P14		- BI33					ien.el	control motorized switches. The power
133	P16					1		4736	relays are interlocked so only one relay
	· · · · · · · · · · · · · · · · · · ·	L						LSA	to avoid shorting out the power supply.
									The power relay pairs are BO6/BO7,
									BO8/BO9, BO13/BO14, BO15/BO16.
									It used for protection purposes only one
									binary output of a pair can be used.

Fig. 5/125 7SJ647 connection diagram part 1; continued on following page

Siemens SIP · Edition No. 8 5/117

### **Connection diagram**



\*) For pinout of communication ports see part 14 of this catalog. For the allocation of the terminals of the panel surface-mounting version refer to the manual (http://www.siemens.com/siprotec).

Fig. 5/126 7SJ647 connection diagram part 2